



**STAND PIPE DETAIL**

**NOTES:**

1. ALL HARDWARE SHALL BE 316 STAINLESS STEEL (NUTS, BOLTS, BRACKETS, BANDING, RESTRAINTS, MOUNTS, ETC).
2. FLOOR DRAIN SHALL BE ZURN Z450B-V.
3. UPSTREAM MANHOLE AND STAND PIPE SHALL BE LAID OUT AS CLOSE TO EACH OTHER AS POSSIBLE AT A DISTANCE FROM LIFT STATION THAT ALLOWS LIFT STATION TO BE EXCAVATED WITHOUT DISTURBING BYPASS OPERATION.