36"

48"

18"

SERVICE = 120/240 VAC
3 PHASE
INTERRUPT RATING 10KA

EMERGENCY POWER   NORMAL POWER

ON   ON
OFF   OFF

MAINTENANCE
RECEPTACLE
HEATER
SPARE
CONTROLS

1   2

3   4   5
G   A   G

6   7   8
A   A

9   10   11
         R

12   13   14
R   R   R

15   16   17
R   R   R

18   19   20
R   R

24   25

PUMP 1   PUMP 2

ON   ON
OFF   OFF

21   22   23

FRONT VIEW WITH OUTER DOOR OPEN

City Plate No.:	STANDARD DETAILS	
P-03		
Last Revision:		**City of Minot**
12/18/2020	LIFT STATION CONTROL PANEL	
Section:		
4000		