



NOTES:

1. PUMPER CONNECTION SHALL FACE THE STREET.
2. HYDRANTS SHALL BE 9'-0" BURY
3. ENCASE HYDRANT BARREL WITH 8 MIL POLY.
4. GATE VALVE BOX PER SEPARATE STANDARD DETAIL.

City Plate No.:	
WAT-1	
Last Revision:	
1/21/2025	
Section:	
2100	

STANDARD DETAILS
HYDRANT

City of Minot