



NOTES:

1. PUMPER CONNECTION SHALL FACE THE STREET.
2. HYDRANT SHALL BE 9'-0" BURY.
3. ENCASE HYDRANT BARREL IN 8 MIL POLY.
4. GATE VALVE BOX PER SEPARATE STANDARD DETAIL.

City Plate No.:

WAT-2

Last Revision:

1/21/2025

Section:

2100

STANDARD DETAILS

**HYDRANT
WITH VERTICAL BEND**

City of Minot